
Red Hill Hydro Corridor

— An Overview of NERC —

The North American Electric Reliability Corporation

Nonprofit corporation based out of Atlanta

Works with utilities to develop standards for power system operations

Has developed a vegetation management standard that applies across North America

This standard applies in Ontario through a memorandum of understanding signed by the Ontario Energy Board and NERC

What NERC Requires

The NERC vegetation management standard is essentially a performance based standard. Its two overarching requirements are:

- 1) That there be annual inspections of hydro corridors
- 2) That there is no encroachment within the “Minimum Vegetation Clearance Distance” (MVCD)

The MVCD is the minimum buffer needed to prevent flashover

NERC uses the ‘Gallet Equation’ to calculate the MVCD. According to NERC this approach to calculating the MCVD is ‘well known for its

**TABLE 1 — Minimum Vegetation Clearance Distances (MVCD)
For Alternating Current Voltages**

(AC) Nominal System Voltage (kV)	(AC) Maximum System Voltage (kV)	MVCD	MVCD	MVCD	MVCD	MVCD	MVCD	MVCD	MVCD	MVCD	MVCD
		feet (meters) Sea level	feet (meters) 3,000ft (914.4m)	feet (meters) 4,000ft (1219.2m)	feet (meters) 5,000ft (1524m)	feet (meters) 6,000ft (1828.3m)	feet (meters) 7,000ft (2133.6m)	feet (meters) 8,000ft (2438.4m)	feet (meters) 9,000ft (2743.2m)	feet (meters) 10,000ft (3048m)	feet (meters) 11,000ft (3352.8m)
765	800	8.06ft (2.46m)	8.89ft (2.71m)	9.17ft (2.80m)	9.45ft (2.88m)	9.73ft (2.97m)	10.01ft (3.05m)	10.29ft (3.14m)	10.57ft (3.22m)	10.85ft (3.31m)	11.13ft (3.39m)
500	550	5.06ft (1.54m)	5.66ft (1.73m)	5.86ft (1.79m)	6.07ft (1.85m)	6.28ft (1.91m)	6.49ft (1.98m)	6.7ft (2.04m)	6.92ft (2.11m)	7.13ft (2.17m)	7.35ft (2.24m)
345	362	3.12ft (0.95m)	3.53ft (1.08m)	3.67ft (1.12m)	3.82ft (1.16m)	3.97ft (1.21m)	4.12ft (1.26m)	4.27ft (1.30m)	4.43ft (1.35m)	4.58ft (1.40m)	4.74ft (1.44m)
230	242	2.97ft (0.91m)	3.36ft (1.02m)	3.49ft (1.06m)	3.63ft (1.11m)	3.78ft (1.15m)	3.92ft (1.19m)	4.07ft (1.24m)	4.22ft (1.29m)	4.37ft (1.33m)	4.53ft (1.38m)
161*	169	2ft (0.61m)	2.28ft (0.69m)	2.38ft (0.73m)	2.48ft (0.76m)	2.58ft (0.79m)	2.69ft (0.82m)	2.8ft (0.85m)	2.91ft (0.89m)	3.03ft (0.92m)	3.14ft (0.96m)
138*	145	1.7ft (0.52m)	1.94ft (0.59m)	2.03ft (0.62m)	2.12ft (0.65m)	2.21ft (0.67m)	2.3ft (0.70m)	2.4ft (0.73m)	2.49ft (0.76m)	2.59ft (0.79m)	2.7ft (0.82m)
115*	121	1.41ft (0.43m)	1.61ft (0.49m)	1.68ft (0.51m)	1.75ft (0.53m)	1.83ft (0.56m)	1.91ft (0.58m)	1.99ft (0.61m)	2.07ft (0.63m)	2.16ft (0.66m)	2.25ft (0.69m)
88*	100	1.15ft (0.35m)	1.32ft (0.40m)	1.38ft (0.42m)	1.44ft (0.44m)	1.5ft (0.46m)	1.57ft (0.48m)	1.64ft (0.50m)	1.71ft (0.52m)	1.78ft (0.54m)	1.86ft (0.57m)
69*	72	0.82ft (0.25m)	0.94ft (0.29m)	0.99ft (0.30m)	1.03ft (0.31m)	1.08ft (0.33m)	1.13ft (0.34m)	1.18ft (0.36m)	1.23ft (0.37m)	1.28ft (0.39m)	1.34ft (0.41m)

How Other Utilities Implement NERC's standards

National Grid's Transmission Right-of-Way Management Program:

Objective: "Establish and maintain cost-effective treatment schedules for each electric ROW"

Strategy : "Shorter cycles (e.g. four and six years) may be established for ROWs that follow highly visible highway corridors, or on lines passing through predominately residential areas that require more selective or more frequent pruning and non-herbicide methods."

How Other Utilities Implement NERC's standards

BC Hydro's vegetation management guidelines are less conscientious but do acknowledge that in some instances selective control and pruning may be substituted for more drastic clearing techniques.

Conduision

There is nothing in the NERC standards that prevents consultation and accommodation for vegetation maintenance along corridors near residential areas.

Proper consultation and accommodation must take place if Hydro One wants to behave as a responsible corporate citizen.

Consulation could potentially save the City, Hydro One and Residents time and money.



Photos of the flooding that occurred in July, 2009.

Questions?

