

Summary of Proposed Parameter Amendments to SUB 14-090

	Parameter	Existing Limit	Recommended limit (mg/l) unless otherwise stated	Comment
Sanitary Discharges (Schedule B)	BOD	300	300	No change
	TSS	350	350	No change
	TP	10	10	No change
	TKN	100	100	No change
	O&G (An./Veg.)	150	150	No change
	Arsenic	1	1	No change
	Cadmium	0.7	0.7	No change
	Cobalt	5	5	No change
	Chromium	5	5	No change
	Copper	2	2	No change
	Mercury	0.01	0.01	No change
	Molybdenum	1	1	No change
	Nickel	2	2	No change
	Lead	2	2	No change
	Selenium	1	1	No change
	Zinc	3	2	Reduce limit
	chloroform	0.04	0.04	No change
	Bis(2-ethyl) Phthalate (DEHP)	0.012	0.28	Increase
	Dibutylphthalate (DBP)	0.08	0.08	No change
	Iron	50	50	No change
	pH	5.5 – 9.5	6-11	Raised min. and max.
	Temperature (max C)	65	60 degrees C	Decrease
	Sulphate	1500	1500	No change
Sulphide (as H ₂ S)	No current limit	1	NEW PARAMETER	
Storm Discharges (Schedule C)	TSS	15	15	No change
	O&G (an./veg)	10	10	No change
	Zinc (total)	3	0.5	Decreased
	Chromium (total)	1	0.08	Decreased
	Lead (total)	1	0.12	Decreased
	Nickel (total)	1	0.08	Decreased
	Copper (total)	1	0.05	Decreased
	Cadmium (total)	1	0.008	Decreased
	Phenolic Compounds	0.02	0.02	No change
	Phosphorus (total)	No current limit	0.4	NEW PARAMETER
	pH	5.5 – 9.5	6-11	Raised min. and max.
Temperature (max C)	65	60 degrees C	Decrease	